

Monthly Fire Log for 2015-2018

Fire Log 2015

Date	Time	Report Number	Location	Description	Disposition	Damage Est.
1/28/15	9:02 PM	J2015 1282015	Smith dorm	Alarm drop Candles burning	PPFP responded candles removed from room student informed of rules on candles	\$0
2/17/15	11:30	F20152172015	Library	Alarm drop burnt popcorn	PPFD responded burnt popcorn in microwave Alarm re-set	\$0
2/20/15	10:00	F2015202202015	Dorms	Fire Drills system check	Smith, Grace, Murphy	
3/11/15	10:00 PM	M201503112015	Pilla	Alarm drop from kitchen area	Guard responded and found a pot smoking . PPFD arrived after he removed source of smoke from the building. PPFD set up fans to exhaust smoke from the area re-set alarm once smoke was cleared.	\$50.00 est.
3/12/15	11:55 AM	M201503122015	Library	Alarm drop ground floor	PPFD responded found smoke detector in electrical closet went off do to drilling dust, cleared the dust and re-set alarm	\$0
3/10/15	12:30				Fire alarm testing & Drill Grace, Murphy. Smith	

4/15/15	9:30 AM	A201504152015	Dorms	Fire Drills	Grace, Smith, Murphy	
5/12/2015	11AM			Fire drills Mullen Besse Dauby		
5/11/15	9:30 AM			Fire Drills Pilla		
5/16/15	2:51 AM	J201505162015	Besse	Alarm drop smoke head hallway	PPFP responded ,faulty head cleared and re-set	0
6/16/15	2:35 AM	J201506162015	Besse	Alarm drop	PPFD responded re-set clear	0
6/15/15	1:08 AM	J20156162015	Besse	Alarm drop	PPFD responded re-set clear	0
8/22/15	1:00PM	A201508222015	Dorm Area	Report of a trouble alarm on panel	National fire checked system and found a smoke detector tampered with and remounted detector	0
10/20/15	12:30pm - 1:35pm		Mullen, Besse, Stano, Parker, Dauby, Pilla	Fire Drills		0
10/23/15	7AM	O201510232015	Besse	Alarm drop	Smoke alarm basement level,PPFD responded re-set system	0
11/24/15	10:30 AM		Smith Grace, Murphy	Fire Drills		

No incidents to report for July 2015, September 2015, and December 2015

Fire Log 2016

Date	Time	Report Number	Location	Description	Disposition	Damage Est.
4/13/16	7:15 PM		Besse library	Fire Drill		
4/24/16	3:00PM	A201604242016	Grace Dorm	Alarm Drop	Microwave oven overheated PPFDF responded cleared smoke and re-set alarm	0
4/24/16	9:30 AM		Pilla, Stano,<Dauby	Fire Drills		
4/24/21016	2:15		Mullen ,Besse	Fire Drills		
4/29/16	9:45 AM		Grace ,Murphy,Smith	Fire Drills		
5/23/16	1:04 AM	M2016 5232016	Murphy Dorm	Alarm Drop	Hair spray set off alarm PPFDF responded and re-set alarm	0
8/ 18/2016	9:24 PM	A20168182016	Smith Dorm	Alarm Drop	Hair dryer set off alarm PPFDF responded and re-set alarm	0
9/11/16	5:52 PM	S20169112016	Grace Dorm	Alarm Drop	Hair dryer and Hair straightener over heated	0
9/11/16	12:30 PM	S02619112016B	Murphy Dorm	Alarm Drop	Smoke detector battery appeared to be weak replaced batter but went off again 1 hour later .Detector replaced	0
9/16 2016	11:30 AM		Grace Dorm	Fire drill		0
11/6/16	10:41 AM		Besse library	Alarm Drop	Alarm drop due to power outage PPFDF re-set alarm	0

No incidents to report for January 2016, February 2016, March 2016, June 2016, July 2016, and December 2016.

Fire Log 2017

Date	Time	Report Number	Location	Description	Disposition	Damage Est.
1/12 2017	1:00 PM	J20160122016	Mullen Bldg.	Microwave Overheated	Received a call of smoke on third floor. Food in microwave over cooked smoke cleared from area	0
4/28/17	10:00 AM		Dorm area	Fire drills		0
5/5/17	10:15 AM	False alarm	Library	Alarm Drop	Alarm went off at the library.PPFP responded checked the building and re-set the alarm.	0
8/21 2017	9:05 AM		Smith Dorm	Alarm Drop	Alarm at Smith dorm PPFD responded checked building re-set alarm ,possible hair dyer overheated	0
9/22/17	10;00 AM	Fire Drills	Dorm Area	Fire drills		
10/5/17	6:50 PM	O2017100520 17	Grace Dorm	Alarm Drop	Flat iron Overheated Alarm re-set	0
10/13/17	5:10 PM	O2017013201 7	Grace Dorm	Alarm Drop	Flat Iron overheated PPFD re-set alarm	0
10/28/17	6:50 PM	O2017102820 17	Grace Dorm	Alarm Drop	Flat Iron overheated PPFD re-set alarm	0
12/2/17	9:00 PM	D2017120220 17	Grace Dorm	Alarm Drop	Flat Iron overheated PPFD re-set alarm	0

No incidents to report for February 2017, March 2017, June 2017, July 2017, and November 2017.

Fire Log 2018

Date	Time	Report Number	Location	Description	Disposition	Damage Est.
------	------	---------------	----------	-------------	-------------	-------------

3/3/18	9:20 AM	Fire Drills	Pilla /Acad. Buildings	Fire Drill		
3/17/18	10:35 PM	M201803172018	Grace dorm	Alarm Drop	Unknown reason/ system re-set	0
4/7/18	5:40 PM	A201804072018	Smith Dorm	Alarm Drop	Over cooked popcorn PPF re-set alarm	0
6/13/18	9:45 AM	Fire Drills	Mullen	Pull station pulled	system re-set	0
7/11/18	10:45 PM	alarm pulled	Mullen	Pull station pulled	Acidental / system re-set	0
8/30/18	5:50PM	alarm Drop	Grace Dorm	Alarm Drop	Overheated Hair dryer System Re-Set	0
9/15/18	4:30 PM	Alarm Pulled	Stano	Pull Station Pulled	Child pulled station PPF re-set system	0
9/19/18	11:15 PM	Alarm drop	Besse	Alarm Drop	Unknown System Re-set	0

No incidents to report for January 2018, February 2018, and May 2018