Monthly Fire Log for 2015-2024

Date	Time	Report Number	Location	Description	Disposition	Damage Est.
1/28/2015	9:02 PM	J2015 1282015	Smith dorm	Alarm drop Candles burning	PPFP responded candles removed from room student informed of rules on candles	$0
2/17/2015	11:30	F20152172015	Library	Alarm drop burnt popcorn	PPFD responded burnt popcorn in microwave Alarm re-set	$0
2/20/2015	10:00	F2015202202015	Dorms	Fire Drills system check	Smith,Grace,Murphy	
3/11/2015	10:00 PM	M201503112015	Pilla	Alarm drop from kitchen area	Guard responded and found a pot smoking. PPFD arrived after he removed source of smoke from the building. PPFD set up fans to exhaust smoke from the area re-set alarm once smoke was cleared.	$50.00 est.
3/12/2015	11:55 AM	M201503122015	Library	Alarm drop ground floor	PPFD responded found smoke detector in electrical closet went off do to drilling dust, cleared the dust and re-set alarm	$0
3/10/2015	12:30				Fire alarm testing & Drill Grace, Murphy. Smith	
4/15/2015	9:30 AM	A201504152015	Dorms	Fire Drills	Grace, Smith, Murphy	
5/12//2015	11AM			Fire drills Mullen Besse Dauby		
5/11/2015	9:30 AM			Fire Drills Pilla		
5/16/2015	2:51 AM	J201505162015	Besse	Alarm drop smoke head hallway	PPFP responded, faulty head cleared and re-set	0
6/16/2015	2:35 AM	J201506162015	Besse	Alarm drop	PPFD responded re-set clear	0
6/15/2015	1:08 AM	J20156162015	Besse	Alarm drop	PPFD responded re-set clear	0
NO INCIDENTS TO REPORT FOR JULY 2015						
8/22/2015	1:00PM	A201508222015	Dorm Area	Report of a trouble alarm on panel	National fire checked system and found a smoke detector tampered with and remounted detector	0
NO INCIDENTS TO REPORT FOR SEPTEMBER 2015						
10/20/2015	12:30pm - 1:35pm		Mullen, Besse, Stano, Parker, Dauby, Pilla	Fire Drills		0
10/23/2015	7AM	O201510232015	Besse	Alarm drop	Smoke alarm basement level, PPFD responded re-set system	0
11/24/2016	10:30 AM		Smith Grace, Murphy	Fire Drills		
NO INCIDENTS TO REPORT FOR DECEMBER 2015						
NO INCIDENTS TO REPORT FOR JANUARY 2016						
NO INCIDENTS TO REPORT FOR FEBRUARY 2016						
NO INCIDENTS TO REPORT FOR MARCH 2016						
4/13/2016	7:15 PM		Besse library	Fire Drill		
4/24/2016	3:00PM	A201604242016	Grace Dorm	Alarm Drop	Microwave oven overheated PPFD responded cleared smoke and re-set alarm	0
4/24/2016	9:30 AM		Pilla, Stano,<Dauby	Fire Drills		
4/24/21016	2:15		Mullen ,Besse	Fire Drills		
4/29/2016	9:45 AM		Grace ,Murphy,Smith	Fire Drills		
5/23/2016	1:04 AM	M2016 5232016	Murphy Dorm	Alarm Drop	Hair spray set off alarm PPFD responded and re-set alarm	0
NO INCIDENTS FOR JUNE 2016						
NO INCIDENTS FOR JULY 2016						
8/ 18/2016	9:24 PM	A20168182016	Smith Dorm	Alarm Drop	Hair dryer set off alarm PPFD responded and re-set alarm	0

9/11/2016	5;52 PM	S20169112016	Grace Dorm	Alarm Drop	Hair dryer and Hair straightener over heated	0
9/11/2016	12:30 PM	S02619112016B	Murphy Dorm	Alarm Drop	Smoke detector battery appeared to be weak replaced battery but went off again 1 hour later. Detector replaced	0
9/16 2016	11:30 AM		Grace Dorm	Fire drill		0
NO INCIDENTS FOR OCTOBER 2016						
11/6/2016	10:41 AM		Besse library	Alarm Drop	Alarm drop due to power outage PPFD re-set alarm	0
NO INCIDENTS FOR DECEMBER 2016						
1/12 2017	1:00 PM	J20160122016	Mullen Bldg.	Microwave Overheated	Received a call of smoke on third floor. Food in microwave over cooked smoke cleared from area	0
NO INCIDENTS FOR FEBRUARY 2017						
NO INCIDENTS FOR MARCH 2017						
4/28/2017	10:00 AM		Dorm area	Fire drills		0
5/5/2017	10:15 AM	False alarm	Library	Alarm Drop	Alarm went off at the library. PPFP responded checked the building and re-set the alarm.	0
NO INCIDENTS FOR JUNE 2017						
NO INCIDENTS FOR JULY 2017						
8/21 2017	9:05 AM		Smith Dorm	Alarm Drop	Alarm at Smith dorm PPFD responded checked building re-set alarm, possible hair dyer overheated	0
9/22/2017	10;00 AM	Fire Drills	Dorm Area	Fire drills		
10/5/2017	6:50 PM	O201710052017	Grace Dorm	Alarm Drop	Flat iron Overheated Alarm re-set	0
10/13/2017	5:10 PM	O20170132017	Grace Dorm	Alarm Drop	Flat Iron overheated PPFD re-set alarm	0
10/28/2017	6:50 PM	O201710282017	Grace Dorm	Alarm Drop	Flat Iron overheated PPFD re-set alarm	0
NO INCIDENTS FOR NOVEMBER 2017						
12/2/2017	9:00 PM	D201712022017	Grace Dorm	Alarm Drop	Flat Iron overheated PPFD re-set alarm	0
NO INCIDENTS FOR JANUARY 2018						
NO INCIDENTS FOR FEBRUARY 2018						
3/3/2018	9:20 AM	Fire Drills	Pilla /Acd. Buildings	Fire Drill		
3/17/2018	10:35 PM	M201803172018	Grace dorm	Alarm Drop	Unknown reason/system re-set	0
4/7/2018	5:40 PM	A201804072018	Smith Dorm	Alarm Drop	Over cooked popcorn PPFD re-set alarm	0
NO INCIDENTS FOR MAY 2018						
6/13/2018	9:45 AM	Fire Drills	Mullen	Pull station pulled	system re-set	0
7/11/2018	10:45 PM	alarm pulled	Mullen	Pull station pulled	Accidental /system re-set	0
8/30/2018	5:50PM	alarm Drop	Grace Dorm	Alarm Drop	Overheated hair dryer System Re-Set	0
9/15/2018	4:30 PM	Alarm Pulled	Stano	Pull Station Pulled	Child pulled station PPFD re-set system	0
9/19/2018	11:15 PM	Alarm drop	Dauby	Alarm Drop	unknown System Re-set	0
10/17/2018	8:55 AM	Alarm Drop	Dauby	Alarm Drop	Power outage PPFD responded Re-set	0
10/17/2018	8:55AM	Alarm Drop	Mullen	Alarm Drop	Power outage PPFD responded Re-set	0
11/20/2018	11:25 AM	Alarm drop	Dauby	Alarm Drop	Power outage Re-set alarm	0
NO INCIDENTS FOR DECEMBER 2018						
NO INCIDENTS FOR JANUARY 2019						
2/21/2019	12:17 AM	Alarm Drop	Besse	Alarm Drop	Smoke head unknown reason, Re-set	0
NO INCIDENTS FOR MARCH 2019						
NO INCIDENTS FOR APRIL 2019						
NO INCIDENTS FOR MAY 2019						

6/10/2019	2:45 PM	alarm Drop	Murphy	Alarm Drop	Construction dust PPFD responded and re-set	0
NO INCIDENTS FOR JULY 2019						
NO INCIDENTS FOR AUGUST 2019						
9/15/2019	5:54pm	Alarm drop	Mullen	Electrical fire attic	PPFD arrived motor overheated in attic. Fire extinguished by maint. system re-set	$400.00
9/20/2019	10:20	Fire Drill	Murphy	Drill & test after Drill		0
9/23/2019	12:35	Fire Drills	Grace Dorm	Drill		0
9/23/2019	12:50	Fire Drills	Smith Dorm	Drill		0
10/30/2019	8:30	Fire Drills	Dauby, Mullen Parker. Stano, Pilla	Drill	Completed between 8:30 & 9:30 AM	0
11/27/2019	10:30	Fire Drills	Grace murphy Smith	Drill	Completed between 10:30 & 11:00	0
NO INCIDENTS FOR DECEMBER 2019						
1/29/2020	6:40 PM	Alarm Drop	Grace Dorm	Alarm Drop	PPFD notified overheated curling iron. System re-set	0
2/19/2020	10:45 AM	Fire Drills	Grace ,Murphy,Smith	Drill	Completed between 10:45 -11:10	0
NO INCIDENTS FOR MARCH 2020						
NO INCIDENTS FOR APRIL 2020						
NO INCIDENTS FOR MAY 2020						
NO INCIDENTS FOR JUNE 2020						
7/6/2020	8:30	Test & Drill	Besse	Drill & test	Completed between 7:30 AM & 8:30	0
8/19/2020	5:30 AM	Alarm Drop	Besse		PPFD arrived checked building / No alarm	0
9/17/2020	10:00 AM	Fire Drills	Grace Murphy Smith	Fire drills	Completed between 10:00 AM & 11:45	0
11/5/2020	10:30 AM	Alarm drop	Grace		Microwave overcooked food ,smoke on first floor. All residents evacuated and area cleared and re-set alarm	0
12/16/2020	9Am		Mullen	Table Top & evacuation drill		0
12/16/2020	11:00 AM	Fire Drills	Mullen, Besse,Parker ,Dauby, Stano,& Pilla	Drills & evac.	All Drills completed by 11:30 AM	0
1/13/2021	10:14	Alarm drop	Grace		Received a Call from State alarm ,PPFD notified ,arrived on scene checked building .all residents evacuated . Third floor apt cleared caused undermined . Alarm re-set and cleared.	0
1/27/2021	11:30	Fire Drills	Grace, Murphy		Completed by 12:00	0
NO INCIDENTS FOR FEBRUARY 2021						
NO INCIDENTS FOR MARCH 2021						
4/30/2021	9:25 AM	Fire Drills	Grace, Murphy Smith		All drills completed by 10;00Am	0
NO INCIDENTS FOR MAY 2021						
6/19/2021	10:39 AM	Alarm Drop	Stano		PPFD responded and re-set alarm. Child pull a pull station	0
NO INCIDENTS FOR JULY 2021						
NO INCIDENTS FOR AUGUST 2021						
NO INCIDENTS FOR SEPTEMBER 2021						
10/15/2021	10:30 AM	Fire Drills	Pilla, Stano, Mullen, Besse, Parker, Dauby	Fire Drills	All drills completed by 11:30AM	
10/28/2021	4:00 PM	O202110282021	Grace	Alarm Drop	Student tripped Smoke Detector using a Hair Iron in room 205. PPFD responded, checked area, reset system.	0
11/3/2021	10:30 AM	Fire Drills	Grace, Murphy, and Smith	Fire Drills	Completed by 11:00 AM Grace (5:15), Murphy (2:10), Smith (3:25)	

11/12/2021	10:05 PM	N202111122021	Smith	Alarm Drop	Student in Smith 250 was making Ramen Noodles, Fire Alarm went off, burnt noodles, PPFD arrived, 10:45 PM all clear given by PPFD, residents allowed to return to building	0
11/26/2021	7:22 AM	N202111222021	Besse Library	Alarm Drop	received call from State Alarm alarm going off at Besse library. PPFD enroute. Checked building no problems fire alarm reset.	
NO INCIDENTS FOR DECEMBER 2021						
NO INCIDENTS FOR JANUARY 2022						
2/4/2022	3:30 PM	F202202042022	grace hall 235	Alarm	set off by hair straightener, PPFD reset	0
3/18/2022	10:00 PM	M202203182022	Murphy Kitchen	Alarm	Set off by cooking food	0
3/21/2022	1:00 PM	Fire Drills	Smith, Murphy, Grace	Fire Drill	Smith 5:09, Murphy 2:30, Grace 5:09	0
3/22/2022	10:00 AM	Fire Drills	Pilla, Stano, Dauby, Parker, Besse, Mullen	Fire Drill	Pilla 3:52, Stano 1:39, Dauby 3:13, Parker 2:47, Besse 2:42, Mullen 5:01	0
NO INCIDENTS FOR APRIL 2022						
NO INCIDENTS FOR MAY 2022						
6/14/2022	2:30 PM	j202206142022	Smith 170	Fire Alarm	Student cooking set of fire alarm	0
NO INCIDENTS FOR JULY 2022						
8/24/2022	9:16 PM	A202208242022	Murphy 208	Fire Alarm	Resident using hair straightener set off due to heat/smoke	0
9/6/2022	1:30 p.m.	Fire Drills	Grace Hall	Fire Drill	evac time 2:30	
9/8/2022	10:10 a.m.	Fire Drills	Murphy Hall	Fire Drill	evac time 2:21	
9/8/2022	10:21 a.m.	Fire Drills	Smith Hall	Fire Drill	evac time 1:44	
9/8/2022	10:32 a.m.	Fire Drills	Grace Hall	Fire Drill	evac time 2:41	
9/8/2022	9:24 p.m.	S202209082022	Murphy Hall	Fire Alarm	Resident of Murphy 101 using a steam cleaning unit	0
NO INCIDENTS FOR OCTOBER 2022						
11/4/2022	1:40 p.m.	Fire Drills	Mullen	Fire Drill	2 minutes 3 seconds	
11/4/2022	1:49 p.m.	Fire Drills	Besse	Fire Drill	2 minutes 40 seconds	
11/4/2022	1:55 p.m.	Fire Drills	Parker Hannifin	Fire Drill	1 minute 9 seconds	
11/4/2022	2:01 p.m.	Fire Drills	Dauby	Fire Drill	1 minute 21 seconds	
11/4/2022	2:06 p.m.	Fire Drills	Stano Athletic	Fire Drill	1 minute 29 seconds	
11/4/2022	2:12 p.m.	Fire Drills	Pilla Ed Ctr	Fire Drill	1 minute 56 seconds	
11/4/2022	9:30 p.m.	Fire Alarm	Smith Hall 150	Alarm	Birthday candles set off alarm	0
11/5/2022	8:35 p.m.	Fire Alarm	Grace Hall 204	Alarm	Students guest vaping set off alarm	0
11/11/2022	7:41 p.m.	Fire Alarm	Smith Hall foyer	Alarm	Student pulled manual fire alarm because she was locked out of the dorm- security phone just outside the entarnce to Smith dorm was functional	0
12/1/2022	1:26 a.m.	Fire Alarm	Grace Hall room213	Fire Alarm	Student was vaping in room 213, 1 student failed to evacuate, student advised she did not hear the alarm or see the flashing lights	0
1/18/2023	1:00 p.m.	Fire Drills	All buildings	Fire Drill	Evac Times: Mullen 5:33, Besse 6:44, PH 2:25, Dauby 2:30, Stano 1:45, Pilla 2:46, Grace 3:10, 2:02, Smith 2:40	

1/30/2023	2:30 p.m.	J202301302023	Murphy Hall	Fire Alarm	Cleaning closet area tripped, no cause found	
1/30/2023	7:00 p.m.	J202310302023b	Smith Hall	Fire Alarm	Res. Of 170 was cooking and the food smoked quickly setting off the alarm, no fire present	
NO INCIDENTS FOR FEBRUARY 2023						
4/19/2023	5:50 p.m.	A202304192023	Grace Hall	Fire Alarm	room 215 alarm set off by hair equipment	0
4/20/2023	1:45 p.m.	DRILLS	Campus Wide	Fire Drills	Evac times: Mullen 3:41, Besse 3:15, PH 1:41, Dauby 3:08, Stano 1:22, Pilla 2:32, Grace 3:00, Murphy 2:49, Smith 3:48	
4/20/2023	9:05 p.m.	A202304202023	Pilla Center	Fire Alarm	2nd floor pull station malfunction, FD reset	
	No Incidents May, 2023					
6/15/2023	4:50 a.m.	J202306152023	Murphy Hall	Fire Alarm	Alarm set off by student resident using hair straightener, no fire present	
6/24/2023	2:44 p.m.	J202306242023	Smith Hall	Fire Alarm	Alarm set off by camp member cooking Smith 320	
7/18/2023	1:41 p.m.	J202307182023	Mullen	Fire Alarm	Alarm set off by dust from brick contractor, PPFD reset	
8/14/2023	1040 a.m.	DRILLS	Grace Hall	Fire Drill	RA training	
8/31/2023	1:00 p.m.	Fire Drills	Stano,Dauby,Parker,Besse, Mullen	Fire drill	Evac times: Stano 1:24, Dauby 2:17, Parker 2:09, Besse 2:21, Mullen 3:24	
9/1/2023	10:00 a.m.	Fire Drills	Pilla, Grace,Murphy, Smith	Fire drill		
10/4/2023	1145 am	fire alarm	murphy hall	alarm drop	PPFD responded unknow cause, building completely evacuated	
10/10/2023	1:22 AM	fire alarm	Grace Hall	alarm drop	PPFD responded unknow cause, building evacuated, report of some residents sleeping through the alarm	
NO INCIDENTS NOVEMBER 2023						
NO INCIDENTS DECEMBER 2023						
1/11/2024	9:40 AM	J202401112024	Smith Hall	alarm drop	Resident of smith 140A set off alarm using heated hair appliance	
1/19/2024	11:30 AM	J202401192024A	Smith Hall	alarm drop	3rd floor stove residents cooking burned pancakes, FD reset alarm	
1/19/2024	9:28 PM	J202401192024B	Smith Hall	alarm drop	Residents cooking, burned food setting off the alarm. FD shut down the stove since it was 2nd time here for burned food at same location	
1/31/2024	11:51 AM	J202401312024	Smith Hall	alarm drop	residents cooking using an air fryer in suite 260, visible smoke in the suite, FD cleared the alarm board	
2/8/2024	8:30 PM	Evening Fire drill	Smith Hall, Murphy Hall, Grace Hall	Fire Drill	Evacuation times: Smith 4:02, Murphy 2:33, Grace 3:17	
3/8/2024	2:23 AM	M202403082024	Grace Hall 208	Fire Alarm	Room 208 smoke indicated, smoke filled room with odor of marijuana, resident not on scene. Lighters and small amount of suspected marijuana present on a table.	

3/21/2024	11:04pm	M202403212024	Grace Hall	Fire alarm	Residents of 312 had a space heater, RA confiscated it. PPFD cleared the alarm board	
4/10/2024	5:40 AM	A202404102024	Murphy Hall	Fire Alarm	Room 110 burnt toast set off fire alarm, FD reset the alarm board	
4/16/2024	6:pm	A202404162024	smith hall	Fire Alarm	Resident of 230A hair dryer set off alarm, FD reset alarm board	
4/25/2024	10:20am	Fire Drills	all buildings	fire drill	Fire Drill conducted all buildings: Evac times, Stano 1:20, Dauby 2:07, Parker Hannifin 1:36, Besse Library 2:35, Mullen 3:46 MU 130 caused failure to due test takers not evac, Frace Hall 3:29, Murphy Hall 2:34, Smith Hall 5:11	
5/16/2024	5:50pm	fire alarm	Smith Hall	Fire Alarm	A young child guest of a resident activated the emergency pull station in the lobby of Smith Hall. PPFD reset the alarm panel	
6/8/2024	10:04 PM	fire alarm	Murphy Hall	Fire Alarm	Person overcooked items in microwave setting off fire alarm, FD reset the alarm panel	
8/26/2024	9:03 p.m.	fire alarm	Grace Hall	Fire alarm	Air Fryer was being used in room 213 set off alarm, FD reset the alarm panel	
8/30/2024	9:30 a.m.	fire alarm	Grace Hall	Fire Alarm	Room 220 fire alarm set off by hair straightener, FD reset the alarm panel	
9/4/2024	1:15 PM	Fire Drills	Grace, Smith, & Murphy hall	Fire drills	Smith 1:58, Murphy 1:57, Grace 2:38	
9/4/2024	8:51 PM	S202409042024A	Grace Hall	alarm drop	Alarm in room where residents were using a vacuum, no cause was evident, FD reset panel	
9/4/2024	10:57 PM	S202409042024B	Murphy Hall	alarm drop	Room 110, hair straightener in use which set off the alarm, FD reset panel	
9/5/2024	10:15 AM	Fire Drills	Stano,Dauby,Parker,Besse, Mullen, Pilla	Drills	Stano 58 seconds, Dauby 1:44, Parker 1:29, Besse 2:07, Mullen 2:15, Pilla 2:21	
9/17/2024	5:40 PM	fire alarm	Grace Hall	alarm drop	Fire alarm in room 312, residents stated they were using Febreeze, FD reset the alarm panel	
9/26/2024	11:22 PM	S202409262024	Grace Hall	alarm drop	Room 213, candle and lighter found in the room, items confiscated by RLC. FD reset the alarm	
10/4/2024	4:24PM	O202410042024	Grace Hall	alarm drop	Room 222, overheated hair dryer set off alarm, FD reset alarm	
10/16/2024	5:13 PM	O202410162024	Grace Hall	alarm drop	Room 203, overheated hair dryer,FD reset alarm panel	
10/22/2024	7:55 AM	O202410222024	Grace Hall	alarm drop	Room 223, diffuser the lkely cause, FD reset alarm panel	
11/5/2024	7:18 AM	N202411052024	Smith Hall	Alarm drop	Room 340D, hair straightener in useset off alarm, FD reset panel	
11/19/2024	8:02 PM	N202411192024	Grace Hall	Alarm Drop	Room 350 cooking set off alarm, FD reset the alarm panel	
11/20/2024	1:12 PM	N202411202024	Murphy Hall	Alarm Drop	Room 310 hair dryer set off alarm, FD reset the alarm panel	

11/25/2024	7:50PM	N202411252024	Grace Hall	Alarm Drop	Room 218 hair appliance in use set off the alarm, FD reset the panel	
12/9/2024	9:30pm	D202412092024	Grace Hall	Alarm Drop	Room 208, aerosol can may have been the cause of the alarm activation. FD reset the panel.	
1/19/2025	5:52PM	J202501192025	Murphy Hall	Alarm Drop	Laundry room, no cause found by FD, FD reset panel	
1/24/2025	12:15 AM	J202501242025	Grace Hall	Alarm Drop	Hair Dryer in a room not listed on the report was the cause, FD reset the alarm panel	
1/31/2025	11:35PM	J202501312025	Grace Hall	Alarm Drop	Hair Straightener in use Grace #219, FD responded, checks ok, FD reset panel	
2/4/2025	9:45PM	F202502042025	Grace Hall	Alarm Drop	Possibly hair dryer set off alarm, FD reset	
2/5/2025	6:00AM	F202502052025A	Grace Hall	Alarm Drop	Unknown cause, poss. Bad smokehead. FD reset. Grace 303	
2/5/2025	6:04AM	F202502052025B	Grace Hall	Alarm Drop	Unknown cause, poss. Bad smokehead. FD reset. Grace 303	
2/9/2025	7:52PM	F202502092025	Murphy Hall	Alarm Drop	Laundry room, no cause found by FD, FD reset panel, recommend keeping laundry room door closed to to heat from dryer	
2/11/2025	5:08PM	F202502112025A	Grace Hall	Alarm Drop	Room 222, possible aerosol spray set alarm off, FD reset the panel	
2/11/2025	5:25PM	F202502112025B	Grace Hall	Alarm Drop	Room 222, possible aerosol spray set alarm off, FD reset the panel smoke head to be checked on 2/12/25 by maintenance	
3/4/2025	1035-1137am	Fire Drills	All buildings	Fire Drill	Smith Hall 3:15, Murphy Hall 3:03, Grace Hall 3:55, Pilla 2:00, Stano 1:40, Dauby 1:47, Parker 1:21, Besse 2:09, Mullen 3:23	
3/18/2025	8:50pm	evening fire drill	Grace, Murphy, Smith Residence Halls	Fire Drill	evening fire alarm drill conducted evacuation times: Smith 4:40, Murphy 3:31, Grace 5:37	
3/19/2025	9:05PM	M202503192025	Grace Hall	Fire Alarm drop	Room 238 flat iron in use, FD reset panel	
3/27/2025	4:05PM	M202503272025	Grace Hall	Alarm Drop	Spray deodorant set off smokehead in Room 223, FD reset the panel	
3/29/2025	2:34PM	M20250329025	Grace Hall	Alarm Drop	room 203 hair straightener in use, FD reset the panel	
4/5/2025	8:23PM	A202504052025	Murphy Hall	Alarm Drop	1st floor laundry room, unknown cause, FD reset the fire panel	
4/6/2025	4:45PM	A202504062025A	Murphy Hall	Alarm Drop	1st floor laundry room, unknown cause, FD reset the fire panel	
4/6/2025	11:27PM	A202504062025B	Grace Hall	Alarm Drop	Room 216, Vape pen found, was possible cause, vape pen confiscated. FD reset the panel	
4/7/2025	8:00 PM	A202504072025	Grace Hall	Alarm Drop	Room 237, nothing found by FD, FD reset the panel	
4/29/2025	3:47AM	A202504292025	Mullen	Alarm Drop	314 kiln room, vents not on causing room temp. increase. FD reset panel , vents turned on by security	
4/29/2025	12:12PM	A202504292025B	Grace Hall	Alarm Drop	Room 219, unknown cause, FD mentioned smell of Vanilla in the room. FD reset the panel	

5/2/2025	9:41 PM	M202505022025	Grace Hall	Alarm Drop	238 flat iron in use, FD reset panel, resident advised to open window & turn fan on.	
5/19/2025	5:30 PM	M202505192025	Grace Hall	Alarm Drop	Painters in Grace Hall set off fire alarm, system was placed in test until 8pm	
6/13/2025	244pm	J202506132025	Grace Hall	Alarm Drop	Cooking in kitchen, burnt food was the cause, FD reset the alarm panel	
7/2/2025	905am	J202507022025	Grace Hall	Alarm Drop	Contractors kicked up dust setting the smokehead off, room 240, FD reset the panel	
7/25/2025	2:07 AM	J202507252025	Grace Hall	Alarm Drop	1st floor common area kitchen, unknown cause, FD reset the fire panel	
7/28/2025	7:20PM	J202507282025	Grace Hall	Alarm Drop	1st floor kitchen, possible cause is condensation due to heavy rains, Precision alarm will be out ASAP to check the smokehead at this location. FD reset the panel	
7/29/2025	3:37PM	J202507292025	Grace Hall	Alarm Drop	Kitchen Hall 1st floor, unkown cause, FD reset panel. New Smokehead to be installed	
8/12/2025	1:27PM	DRILL	Grace Hall	Drill	Fire drill with RA team and Pepper Pike safety forces	
8/12/2025	1:47PM	DRILL	Grace Hall	Drill	Fire drill with RA team and Pepper Pike safety forces	
8/21/2025	6:30PM	A202508212025	Grace Hall	Alarm Drop	Room 237 hair dryer in use, heat set off the alarm, FD reset the panel	
8/23/2025	8:13AM	A202508232025	Grace Hall	Alarm Drop	Alarm in 318, unknown cause, panel would not reset. Precision Alarm sent a tech, tech was able to reset the panel. 318 had the smokehead replaced	
8/25/2025	4:59PM	A202508252025	Grace Hall	Alarm Drop	Alarm in Grace Hall kitchen, resident was cooking food and left it unattended. Burnt food was removed, FD ventilated the area due to smoke. FD reset system.	
8/27/2025	4:23PM	A202508272025	Murphy Hall	Alarm Drop	Room 102 hair straightener brush in use set off the detector, building evacuated, FD personnel reset the alarm panel.	
8/30/2025	5:41 PM	A202508302025	Murphy Hall	Alarm Drop	Room 105 smokehead set off, no apparent reason for the activation, FD reset the alarm panel	
9/2/2025	12:47pm	S202509022025	Smith Hall	Alarm Drop	Room 310D, Hair dryer/straightener in use, vape pen also located by FD personel. FD reset the alarm panel	
9/3/2025	1:05am	S202509032025	Grace Hall	Alarm Drop	Room 241, unknown cause, FD smelled a flowery spray smell. FD reset the alarm panel	
9/3/2025	9:20-9:55am	DRILLS	Pilla Center, Stano, Dauby, Parker, Besse, Mullen	Fire drills	Evac times; Pilla-1:45, Stano-1:24, Dauby 1:44, Parker 1:55, Besse 2:30, Mullen 2:14	
9/3/2025	1pm-1:32pm	DRILLS	Smith,Murphy, & Grace Halls	Fire drills	Evac times; Smith- 3:06, Murphy-2:19, Grace-4:02	

9/26/2025	11:50 PM	S202509262025	Grace Hall	Alarm Drop	Grace 211, unkown cause, FD reset the panel	
9/29/2025	3:29AM	S202509292025	Grace Hall	Alarm Drop	Room 327, unknown cause, FD reset the panel	
10/6/2025	11:30pm	O202510062025	Grace Hall	Alarm Drop	Room 320, possible smoking/vaping in the hall oustide the room. FD reset the panel	
10/8/2025	12:06PM	O202510082025	Pilla Center	Alarm Drop	Irrigation tech set off the fire alarm in course of checking the irrigation system back flow system. FD reset the panel	
10/17/2025	9:45pm	O202510172025	Grace Hall	Alarm Drop	Room 221, adhesive spray in use set off the smokehead. FD reset the panel	
11/8/2025	10:00am	N202511082025A	Murphy Hall	Alarm Drop	Room 310, Hair Straightener in use,heat from device set off smokehead. No Fire. FD reset the panel	
11/8/2025	11:22PM	N202511082025B	Grace Hall	Alarm Drop	Room 211, cause of alarm unknown according to FD, FD reset the panel	
11/12/2025	10:24AM	N202511122025A	Smith Hall	Alarm Drop	Room 310, unknown cause, FD reset panel	
11/12/2025	10:24PM	N202511122025B	Grace Hall	Alarm Drop	220 hallway smokehead set off, unknown cause, FGD reset the panel	
12/1/2025	8:40PM	D202512012025	Murphy Hall	Alarm Drop	1st floor laundry room, possible ventilation issue, vents not routed correctly according to FD personel, FD reset the panel	
12/10/2025	2:34PM	D202512102025	Grace Hall	Alarm Drop	Room 220, possibly smoking in room, FD reset the panel	
12/11/2025	12:00AM	D202512112025	Murphy Hall	Alarm Drop	Murphy 209, possible aerosol in use with hair straightener. FD reset the panel	
12/16/2025	2:45PM	D202512162025	Murphy Hall	Alarm Drop	Alarm went off in 5 separate locations 21 minutes after testing was complete and the system was online from 225PM. Possible monitoring station issue. The alarm wasn't active upon arrival and the residents advised no alarm went off after testing. No need to reset the panel as it was system normal.	
1/13/2026	9:47PM	J202601132026	Grace Hall	Room 221, spray deodorant in use. FD reset the fire panel		0
1/23/2026	9:00PM	J202601232026	Grace Hall	Room 220 blow dryer in use, FD reset the panel		0
2/1/2026	2:13PM	F202602012026	Grace Hall	Room 314, hair straightener in use, FD reset the panel	P.V.	0
2/3/2026	8:23PM	F202602032026	Grace Hall	Room 208, cologne spray in use, FD reset the panel		0
2/9/2026	7:45AM	F202602092026	Grace Hall	Room 221, spray deodorant in use. FD reset the fire panel		0
2/13/2026	11:30AM	F202602132026A	Murphy Hall	SO. Corridor, smelled like perfume spray in the area, FD reset panel		0

2/13/2026	11:45AM	F202602132026B	Murphy Hall	Hall near Laundry Room, Dryer was being used on high setting, setting off heat sensor, FD reset panel		
2/15/2026	2:30AM	F202602152026	Grace Hall	Kitchen area, burnt food, FD reset the panel		0
3/6/2026	7:00pm		Grace Hall, Murphy Hall, & Smith Hall	Evening Fire Drills conducted in Murphy Dorm, Grace Dorm, & Smith Dorm	Evacuation Times: Grace 3:44, Murphy 3:18, Smith 4:11	
3/16/2026	1:55pm	M202603162026	Grace Hall	Room 319, possible marijuana smoke activated smokehead. FD reset the panel		0
4/2/2026	7:02PM	A202604022026	Grace Hall	Hair dryer, room not stated, FD reset the panel		
4/7/2026	12:07AM	A202604072026	Grace Hall	Room 311 activation, room smelled of perfume spray. FD reset the Panel		
4/13/2026	3:08 PM	A202604132026	Grace Hall	Room 205 activation, smoking in room set off alarm. FD reset the panel		
4/14/2026	1:10PM	A202604142026	Murphy Hall	Room 111, hair dryer in use set of the sensor, FD reset the panel		
4/16/2026	10:20am-1:45pm	FIRE DRILL	Campus Wide	Fire drills conducted for all campus buildings	Evacuation Times (minutes:seconds): Pilla 1:30, Stano 2:41, Dauby 2:07, Parker Hannifin 1:13, Besse 1:43, Mullen 2:59, Smith 1:45, Murphy 2:24, Grace 3:04	
4/21/2026	2:30pm	A202604212026A	Murphy Hall	3rd floor laundry room, food left in the microwave, burned food. FD reset the panel. Microwave was disposed.		100
4/21/2026	3:52pm	A202604212026B	Parker Hannifin	Room 112, unknown cause, FD reset the panel		
5/7/2026	6:07am	M202605072026	Smith Hall	Fire panel battery low, alarm company classified as radio duress. Alarm Co. dispatched police. Police & guard checked Smith Hall, fire panel showed low battery for the fire system. Maintenance notified		
5/12/2026	7:29pm	M202605122026	Grace Hall	Grace first floor rec room kitchen smoke detector. Someone cooking with oil, fire department reset alarm panel. Gina notified.		

5/25/2026	9:02PM	M202605252026	Murphy Hall	Alarm activated at 9:02PM, overcooked food in the kitchen, panel was reset. Panel showing a city/tie Rev Pol trouble, precision alarm notified.		
6/4/2026	1:33AM	J202606042026	Murphy Hall	Alarm near room 106 activated, no cause found, FD reset the panel		
7/13/2026	11:45AM	J202607132026	Pilla Bldg.	A visitor to the Pilla Building became ill, medics were called. Medics treated the patient. Patient did not want to be transported to ER and signed a waiver release. Patient was taken home by a guardian.		
7/24/2026	1035am-1115am	J202607242026	All Buildings except Besse Library	Fire drills conducted for all campus buildings, Evac times as follows: Parker Hannifin- 55 seconds, Dauby 56 seconds, Stano Gym 1 minute 2 seconds, Pilla 1 minute 56 seconds, Grace Hall 1 minute 10 seconds, Murphy Hall 1 minute 9 seconds, Smith Hall 1 minute 7 seconds		
7/30/2026	3:47AM	J202607302026A	Murphy Hall	Fire alarm activation room 205, unknown cause. FD reset the panel		
7/30/2026	4:18AM	J202607302026B	Murphy Hall	Fire alarm activation room 205, unknown cause. FD reset the panel		
8/25/2026	9:09AM	A202608252026	Grace Hall	Room 313, hair straightener in use, FD responded checked the room and reset the alarm panel. Resident advised to use heat based hair appliances in the bathroom		
8/25/2026	3:10PM	A202608252026A	Grace Hall	Room 234, hair spray in use, FD responded, checked the room and reset the fire alarm panel		

9/10/2026	1:05pm-2:19pm	FIRE DRILLS	All Buildings	Fire Drills all bldgs. Time are as follows: Murphy Hall 2:27, Grace Hall 3:17, Smith Hall 2:53, Pilla 5:02, Stano 1:30, Dauby 2:32, Parker 2:38, Besse Library 2:01, Mullen 2:08		
9/14/2026	3:27am	S202609142026	Grace Hall	Room 315, RA reports 315 smelled of marijuana smoke upon entering the room to check for smoke/fire. Guest of resident was told to leave. FD reset the fire panel.		
9/15/2026	7:29pm	S202609152026	Grace Hall	Room 203, hairspray in use set off the alarm. FD reset the fire panel		
9/19/2026	4:15PM	S202609192026	Smith Hall	Room 120B, hairspray or perfume in use, FD reset the panel		
9/24/2026	11:01AM	S202609242026	Grace Hall	Room 229, steam created by running hot water in the bathroom set off the detector. FD reset the panel.		
9/26/2026	12:34AM	S202609262026	Grace Hall	Room 304, multiple fans running, possible that dust set off the detector. No scents detected. FD reset the panel		
9/27/2026	3:54PM	S202609272026	Grace Hall	Room 234, Steam from hot shower with bathroom door left open set off detector. FD reset the panel.		
10/8/2026	10:11 AM	O202610082026	Grace Hall	Room 223, hairspray in use set off the detector, FD reset the panel		
10/11/2026	11:00AM	O202610112026	Smith Hall	Hair Straightener in use set off the detector, FD reset the panel		
10/20/2026	11:49AM	O202610202026	Murphy Hall	Room 111, hair dryer in use set of the detector, FD reset the panel.		
11/3/2026	3:09PM	N202611032026A	Grace Hall	Room 327, flat iron in use set off the detector. FD reset the panel		
11/3/2026	5:44PM	N202611032026B	Grace Hall	Room 243, shower steam open bathroom door set off the detector, FD reset the panel		