

## Monthly Fire Log for 2015-2024

| Date                                      | Time             | Report Number  | Location                                   | Description                        | Disposition                                                                                                                                                                                    | Damage Est.  |
|-------------------------------------------|------------------|----------------|--------------------------------------------|------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|
| 1/28/2015                                 | 9:02 PM          | J2015 1282015  | Smith dorm                                 | Alarm drop Candles burning         | PPFP responded candles removed from room student informed of rules on candles                                                                                                                  | \$0          |
| 2/17/2015                                 | 11:30            | F20152172015   | Library                                    | Alarm drop burnt popcorn           | PPFD responded burnt popcorn in microwave Alarm re-set                                                                                                                                         | \$0          |
| 2/20/2015                                 | 10:00            | F2015202202015 | Dorms                                      | Fire Drills system check           | Smith, Grace, Murphy                                                                                                                                                                           |              |
| 3/11/2015                                 | 10:00 PM         | M201503112015  | Pilla                                      | Alarm drop from kitchen area       | Guard responded and found a pot smoking. PPFD arrived after he removed source of smoke from the building. PPFD set up fans to exhaust smoke from the area re-set alarm once smoke was cleared. | \$50.00 est. |
| 3/12/2015                                 | 11:55 AM         | M201503122015  | Library                                    | Alarm drop ground floor            | PPFD responded found smoke detector in electrical closet went off do to drilling dust, cleared the dust and re-set alarm                                                                       | \$0          |
| 3/10/2015                                 | 12:30            |                |                                            |                                    | Fire alarm testing & Drill Grace, Murphy, Smith                                                                                                                                                |              |
| 4/15/2015                                 | 9:30 AM          | A201504152015  | Dorms                                      | Fire Drills                        | Grace, Smith, Murphy                                                                                                                                                                           |              |
| 5/12/2015                                 | 11AM             |                |                                            | Fire drills Mullen Besse Dauby     |                                                                                                                                                                                                |              |
| 5/11/2015                                 | 9:30 AM          |                |                                            | Fire Drills Pilla                  |                                                                                                                                                                                                |              |
| 5/16/2015                                 | 2:51 AM          | J201505162015  | Besse                                      | Alarm drop smoke head hallway      | PPFP responded, faulty head cleared and re-set                                                                                                                                                 | 0            |
| 6/16/2015                                 | 2:35 AM          | J201506162015  | Besse                                      | Alarm drop                         | PPFD responded re-set clear                                                                                                                                                                    | 0            |
| 6/15/2015                                 | 1:08 AM          | J20156162015   | Besse                                      | Alarm drop                         | PPFD responded re-set clear                                                                                                                                                                    | 0            |
| NO INCIDENTS TO REPORT FOR JULY 2015      |                  |                |                                            |                                    |                                                                                                                                                                                                |              |
| 8/22/2015                                 | 1:00PM           | A201508222015  | Dorm Area                                  | Report of a trouble alarm on panel | National fire checked system and found a smoke detector tampered with and remounted detector                                                                                                   | 0            |
| NO INCIDENTS TO REPORT FOR SEPTEMBER 2015 |                  |                |                                            |                                    |                                                                                                                                                                                                |              |
| 10/20/2015                                | 12:30pm - 1:35pm |                | Mullen, Besse, Stano, Parker, Dauby, Pilla | Fire Drills                        |                                                                                                                                                                                                | 0            |
| 10/23/2015                                | 7AM              | O201510232015  | Besse                                      | Alarm drop                         | Smoke alarm basement level, PPFD responded re-set system                                                                                                                                       | 0            |
| 11/24/2016                                | 10:30 AM         |                | Smith Grace, Murphy                        | Fire Drills                        |                                                                                                                                                                                                |              |
| NO INCIDENTS TO REPORT FOR DECEMBER 2015  |                  |                |                                            |                                    |                                                                                                                                                                                                |              |
| NO INCIDENTS TO REPORT FOR JANUARY 2016   |                  |                |                                            |                                    |                                                                                                                                                                                                |              |
| NO INCIDENTS TO REPORT FOR FEBRUARY 2016  |                  |                |                                            |                                    |                                                                                                                                                                                                |              |
| NO INCIDENTS TO REPORT FOR MARCH 2016     |                  |                |                                            |                                    |                                                                                                                                                                                                |              |
| 4/13/2016                                 | 7:15 PM          |                | Besse library                              | Fire Drill                         |                                                                                                                                                                                                |              |
| 4/24/2016                                 | 3:00PM           | A201604242016  | Grace Dorm                                 | Alarm Drop                         | Microwave oven overheated PPFD responded cleared smoke and re-set alarm                                                                                                                        | 0            |
| 4/24/2016                                 | 9:30 AM          |                | Pilla, Stano, <Dauby                       | Fire Drills                        |                                                                                                                                                                                                |              |
| 4/24/21016                                | 2:15             |                | Mullen ,Besse                              | Fire Drills                        |                                                                                                                                                                                                |              |
| 4/29/2016                                 | 9:45 AM          |                | Grace ,Murphy, Smith                       | Fire Drills                        |                                                                                                                                                                                                |              |
| 5/23/2016                                 | 1:04 AM          | M2016 5232016  | Murphy Dorm                                | Alarm Drop                         | Hair spray set off alarm PPFD responded and re-set alarm                                                                                                                                       | 0            |
| NO INCIDENTS FOR JUNE 2016                |                  |                |                                            |                                    |                                                                                                                                                                                                |              |
| NO INCIDENTS FOR JULY 2016                |                  |                |                                            |                                    |                                                                                                                                                                                                |              |
| 8/ 18/2016                                | 9:24 PM          | A20168182016   | Smith Dorm                                 | Alarm Drop                         | Hair dryer set off alarm PPFD responded and re-set alarm                                                                                                                                       | 0            |
| 9/11/2016                                 | 5:52 PM          | S20169112016   | Grace Dorm                                 | Alarm Drop                         | Hair dryer and Hair straightener over heated                                                                                                                                                   | 0            |

|                                |          |               |                        |                          |                                                                                                                |          |
|--------------------------------|----------|---------------|------------------------|--------------------------|----------------------------------------------------------------------------------------------------------------|----------|
| 9/11/2016                      | 12:30 PM | S02619112016B | Murphy Dorm            | Alarm Drop               | Smoke detector battery appeared to be weak replaced battery but went off again 1 hour later. Detector replaced | 0        |
| 9/16/2016                      | 11:30 AM |               | Grace Dorm             | Fire drill               |                                                                                                                | 0        |
| NO INCIDENTS FOR OCTOBER 2016  |          |               |                        |                          |                                                                                                                |          |
| 11/6/2016                      | 10:41 AM |               | Besse library          | Alarm Drop               | Alarm drop due to power outage PPFd re-set alarm                                                               | 0        |
| NO INCIDENTS FOR DECEMBER 2016 |          |               |                        |                          |                                                                                                                |          |
| 1/12/2017                      | 1:00 PM  | J20160122016  | Mullen Bldg.           | Microwave Overheated     | Received a call of smoke on third floor. Food in microwave over cooked smoke cleared from area                 | 0        |
| NO INCIDENTS FOR FEBRUARY 2017 |          |               |                        |                          |                                                                                                                |          |
| NO INCIDENTS FOR MARCH 2017    |          |               |                        |                          |                                                                                                                |          |
| 4/28/2017                      | 10:00 AM |               | Dorm area              | Fire drills              |                                                                                                                | 0        |
| 5/5/2017                       | 10:15 AM | False alarm   | Library                | Alarm Drop               | Alarm went off at the library. PPFd responded checked the building and re-set the alarm.                       | 0        |
| NO INCIDENTS FOR JUNE 2017     |          |               |                        |                          |                                                                                                                |          |
| NO INCIDENTS FOR JULY 2017     |          |               |                        |                          |                                                                                                                |          |
| 8/21/2017                      | 9:05 AM  |               | Smith Dorm             | Alarm Drop               | Alarm at Smith dorm PPFd responded checked building re-set alarm, possible hair dryer overheated               | 0        |
| 9/22/2017                      | 10:00 AM | Fire Drills   | Dorm Area              | Fire drills              |                                                                                                                |          |
| 10/5/2017                      | 6:50 PM  | O201710052017 | Grace Dorm             | Alarm Drop               | Flat iron Overheated Alarm re-set                                                                              | 0        |
| 10/13/2017                     | 5:10 PM  | O20170132017  | Grace Dorm             | Alarm Drop               | Flat Iron overheated PPFd re-set alarm                                                                         | 0        |
| 10/28/2017                     | 6:50 PM  | O201710282017 | Grace Dorm             | Alarm Drop               | Flat Iron overheated PPFd re-set alarm                                                                         | 0        |
| NO INCIDENTS FOR NOVEMBER 2017 |          |               |                        |                          |                                                                                                                |          |
| 12/2/2017                      | 9:00 PM  | D201712022017 | Grace Dorm             | Alarm Drop               | Flat Iron overheated PPFd re-set alarm                                                                         | 0        |
| NO INCIDENTS FOR JANUARY 2018  |          |               |                        |                          |                                                                                                                |          |
| NO INCIDENTS FOR FEBRUARY 2018 |          |               |                        |                          |                                                                                                                |          |
| 3/3/2018                       | 9:20 AM  | Fire Drills   | Pilla /Accl. Buildings | Fire Drill               |                                                                                                                |          |
| 3/17/2018                      | 10:35 PM | M201803172018 | Grace dorm             | Alarm Drop               | Unknown reason/system re-set                                                                                   | 0        |
| 4/7/2018                       | 5:40 PM  | A201804072018 | Smith Dorm             | Alarm Drop               | Over cooked popcorn PPFd re-set alarm                                                                          | 0        |
| NO INCIDENTS FOR MAY 2018      |          |               |                        |                          |                                                                                                                |          |
| 6/13/2018                      | 9:45 AM  | Fire Drills   | Mullen                 | Pull station pulled      | system re-set                                                                                                  | 0        |
| 7/11/2018                      | 10:45 PM | alarm pulled  | Mullen                 | Pull station pulled      | Accidental /system re-set                                                                                      | 0        |
| 8/30/2018                      | 5:50PM   | alarm Drop    | Grace Dorm             | Alarm Drop               | Overheated hair dryer System Re-Set                                                                            | 0        |
| 9/15/2018                      | 4:30 PM  | Alarm Pulled  | Stano                  | Pull Station Pulled      | Child pulled station PPFd re-set system                                                                        | 0        |
| 9/19/2018                      | 11:15 PM | Alarm drop    | Dauby                  | Alarm Drop               | unknown System Re-set                                                                                          | 0        |
| 10/17/2018                     | 8:55 AM  | Alarm Drop    | Dauby                  | Alarm Drop               | Power outage PPFd responded Re-set                                                                             | 0        |
| 10/17/2018                     | 8:55AM   | Alarm Drop    | Mullen                 | Alarm Drop               | Power outage PPFd responded Re-set                                                                             | 0        |
| 11/20/2018                     | 11:25 AM | Alarm drop    | Dauby                  | Alarm Drop               | Power outage Re-set alarm                                                                                      | 0        |
| NO INCIDENTS FOR DECEMBER 2018 |          |               |                        |                          |                                                                                                                |          |
| NO INCIDENTS FOR JANUARY 2019  |          |               |                        |                          |                                                                                                                |          |
| 2/21/2019                      | 12:17 AM | Alarm Drop    | Besse                  | Alarm Drop               | Smoke head unknown reason, Re-set                                                                              | 0        |
| NO INCIDENTS FOR MARCH 2019    |          |               |                        |                          |                                                                                                                |          |
| NO INCIDENTS FOR APRIL 2019    |          |               |                        |                          |                                                                                                                |          |
| NO INCIDENTS FOR MAY 2019      |          |               |                        |                          |                                                                                                                |          |
| 6/10/2019                      | 2:45 PM  | alarm Drop    | Murphy                 | Alarm Drop               | Construction dust PPFd responded and re-set                                                                    | 0        |
| NO INCIDENTS FOR JULY 2019     |          |               |                        |                          |                                                                                                                |          |
| NO INCIDENTS FOR AUGUST 2019   |          |               |                        |                          |                                                                                                                |          |
| 9/15/2019                      | 5:54pm   | Alarm drop    | Mullen                 | Electrical fire attic    | PPFD arrived motor overheated in attic. Fire extinguished by maint. system re-set                              | \$400.00 |
| 9/20/2019                      | 10:20    | Fire Drill    | Murphy                 | Drill & test after Drill |                                                                                                                | 0        |

|                                 |          |               |                                            |                              |                                                                                                                                                                                     |   |
|---------------------------------|----------|---------------|--------------------------------------------|------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---|
| 9/23/2019                       | 12:35    | Fire Drills   | Grace Dorm                                 | Drill                        |                                                                                                                                                                                     | 0 |
| 9/23/2019                       | 12:50    | Fire Drills   | Smith Dorm                                 | Drill                        |                                                                                                                                                                                     | 0 |
| 10/30/2019                      | 8:30     | Fire Drills   | Dauby, Mullen Parker, Stano, Pilla         | Drill                        | Completed between 8:30 & 9:30 AM                                                                                                                                                    | 0 |
| 11/27/2019                      | 10:30    | Fire Drills   | Grace murphy Smith                         | Drill                        | Completed between 10:30 & 11:00                                                                                                                                                     | 0 |
| NO INCIDENTS FOR DECEMBER 2019  |          |               |                                            |                              |                                                                                                                                                                                     |   |
| 1/29/2020                       | 6:40 PM  | Alarm Drop    | Grace Dorm                                 | Alarm Drop                   | PPFD notified overheated curling iron. System re-set                                                                                                                                | 0 |
| 2/19/2020                       | 10:45 AM | Fire Drills   | Grace ,Murphy,Smith                        | Drill                        | Completed between 10:45 -11:10                                                                                                                                                      | 0 |
| NO INCIDENTS FOR MARCH 2020     |          |               |                                            |                              |                                                                                                                                                                                     |   |
| NO INCIDENTS FOR APRIL 2020     |          |               |                                            |                              |                                                                                                                                                                                     |   |
| NO INCIDENTS FOR MAY 2020       |          |               |                                            |                              |                                                                                                                                                                                     |   |
| NO INCIDENTS FOR JUNE 2020      |          |               |                                            |                              |                                                                                                                                                                                     |   |
| 7/6/2020                        | 8:30     | Test & Drill  | Besse                                      | Drill & test                 | Completed between 7:30 AM & 8:30                                                                                                                                                    | 0 |
| 8/19/2020                       | 5:30 AM  | Alarm Drop    | Besse                                      |                              | PPFD arrived checked building / No alarm                                                                                                                                            | 0 |
| 9/17/2020                       | 10:00 AM | Fire Drills   | Grace Murphy Smith                         | Fire drills                  | Completed between 10:00 AM & 11:45                                                                                                                                                  | 0 |
| 11/5/2020                       | 10:30 AM | Alarm drop    | Grace                                      |                              | Microwave overcooked food ,smoke on first floor. All residents evacuated and area cleared and re-set alarm                                                                          | 0 |
| 12/16/2020                      | 9Am      |               | Mullen                                     | Table Top & evacuation drill |                                                                                                                                                                                     | 0 |
| 12/16/2020                      | 11:00 AM | Fire Drills   | Mullen, Besse,Parker ,Dauby, Stano,& Pilla | Drills & evac.               | All Drills completed by 11:30 AM                                                                                                                                                    | 0 |
| 1/13/2021                       | 10:14    | Alarm drop    | Grace                                      |                              | Received a Call from State alarm ,PPFD notified ,arrived on scene checked building .all residents evacuated . Third floor apt cleared caused undermined . Alarm re-set and cleared. | 0 |
| 1/27/2021                       | 11:30    | Fire Drills   | Grace, Murphy                              |                              | Completed by 12:00                                                                                                                                                                  | 0 |
| NO INCIDENTS FOR FEBRUARY 2021  |          |               |                                            |                              |                                                                                                                                                                                     |   |
| NO INCIDENTS FOR MARCH 2021     |          |               |                                            |                              |                                                                                                                                                                                     |   |
| 4/30/2021                       | 9:25 AM  | Fire Drills   | Grace, Murphy Smith                        |                              | All drills completed by 10:00Am                                                                                                                                                     | 0 |
| NO INCIDENTS FOR MAY 2021       |          |               |                                            |                              |                                                                                                                                                                                     |   |
| 6/19/2021                       | 10:39 AM | Alarm Drop    | Stano                                      |                              | PPFD responded and re-set alarm. Child pull a pull station                                                                                                                          | 0 |
| NO INCIDENTS FOR JULY 2021      |          |               |                                            |                              |                                                                                                                                                                                     |   |
| NO INCIDENTS FOR AUGUST 2021    |          |               |                                            |                              |                                                                                                                                                                                     |   |
| NO INCIDENTS FOR SEPTEMBER 2021 |          |               |                                            |                              |                                                                                                                                                                                     |   |
| 10/15/2021                      | 10:30 AM | Fire Drills   | Pilla, Stano, Mullen, Besse, Parker, Dauby | Fire Drills                  | All drills completed by 11:30AM                                                                                                                                                     |   |
| 10/28/2021                      | 4:00 PM  | O202110282021 | Grace                                      | Alarm Drop                   | Student tripped Smoke Detector using a Hair Iron in room 205. PPFD responded, checked area, reset system.                                                                           | 0 |
| 11/3/2021                       | 10:30 AM | Fire Drills   | Grace, Murphy, and Smith                   | Fire Drills                  | Completed by 11:00 AM Grace (5:15), Murphy (2:10), Smith (3:25)                                                                                                                     |   |
| 11/12/2021                      | 10:05 PM | N202111122021 | Smith                                      | Alarm Drop                   | Student in Smith 250 was making Ramen Noodles, Fire Alarm went off, burnt noodles, PPFD arrived, 10:45 PM all clear given by PPFD, residents allowed to return to building          | 0 |
| 11/26/2021                      | 7:22 AM  | N202111222021 | Besse Library                              | Alarm Drop                   | received call from State Alarm alarm going off at Besse library. PPFD enroute. Checked building no problems fire alarm reset.                                                       |   |
| NO INCIDENTS FOR DECEMBER 2021  |          |               |                                            |                              |                                                                                                                                                                                     |   |
| NO INCIDENTS FOR JANUARY 2022   |          |               |                                            |                              |                                                                                                                                                                                     |   |

|                                |            |                |                                               |             |                                                                                                                                                         |   |
|--------------------------------|------------|----------------|-----------------------------------------------|-------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---|
| 2/4/2022                       | 3:30 PM    | F202202042022  | grace hall 235                                | Alarm       | set off by hair straightener, PPF reset                                                                                                                 | 0 |
| 3/18/2022                      | 10:00 PM   | M202203182022  | Murphy Kitchen                                | Alarm       | Set off by cooking food                                                                                                                                 | 0 |
| 3/21/2022                      | 1:00 PM    | Fire Drills    | Smith, Murphy, Grace                          | Fire Drill  | Smith 5:09, Murphy 2:30, Grace 5:09                                                                                                                     | 0 |
| 3/22/2022                      | 10:00 AM   | Fire Drills    | Pilla, Stano, Dauby,<br>Parker, Besse, Mullen | Fire Drill  | Pilla 3:52, Stano 1:39, Dauby 3:13, Parker 2:47,<br>Besse 2:42, Mullen 5:01                                                                             | 0 |
| NO INCIDENTS FOR APRIL 2022    |            |                |                                               |             |                                                                                                                                                         |   |
| NO INCIDENTS FOR MAY 2022      |            |                |                                               |             |                                                                                                                                                         |   |
| 6/14/2022                      | 2:30 PM    | j202206142022  | Smith 170                                     | Fire Alarm  | Student cooking set of fire alarm                                                                                                                       | 0 |
| NO INCIDENTS FOR JULY 2022     |            |                |                                               |             |                                                                                                                                                         |   |
| 8/24/2022                      | 9:16 PM    | A202208242022  | Murphy 208                                    | Fire Alarm  | Resident using hair straightener set off due to<br>heat/smoke                                                                                           | 0 |
| 9/6/2022                       | 1:30 p.m.  | Fire Drills    | Grace Hall                                    | Fire Drill  | evac time 2:30                                                                                                                                          |   |
| 9/8/2022                       | 10:10 a.m. | Fire Drills    | Murphy Hall                                   | Fire Drill  | evac time 2:21                                                                                                                                          |   |
| 9/8/2022                       | 10:21 a.m. | Fire Drills    | Smith Hall                                    | Fire Drill  | evac time 1:44                                                                                                                                          |   |
| 9/8/2022                       | 10:32 a.m. | Fire Drills    | Grace Hall                                    | Fire Drill  | evac time 2:41                                                                                                                                          |   |
| 9/8/2022                       | 9:24 p.m.  | S202209082022  | Murphy Hall                                   | Fire Alarm  | Resident of Murphy 101 using a steam cleaning<br>unit                                                                                                   | 0 |
| NO INCIDENTS FOR OCTOBER 2022  |            |                |                                               |             |                                                                                                                                                         |   |
| 11/4/2022                      | 1:40 p.m.  | Fire Drills    | Mullen                                        | Fire Drill  | 2 minutes 3 seconds                                                                                                                                     |   |
| 11/4/2022                      | 1:49 p.m.  | Fire Drills    | Besse                                         | Fire Drill  | 2 minutes 40 seconds                                                                                                                                    |   |
| 11/4/2022                      | 1:55 p.m.  | Fire Drills    | Parker Hannifin                               | Fire Drill  | 1 minute 9 seconds                                                                                                                                      |   |
| 11/4/2022                      | 2:01 p.m.  | Fire Drills    | Dauby                                         | Fire Drill  | 1 minute 21 seconds                                                                                                                                     |   |
| 11/4/2022                      | 2:06 p.m.  | Fire Drills    | Stano Athletic                                | Fire Drill  | 1 minute 29 seconds                                                                                                                                     |   |
| 11/4/2022                      | 2:12 p.m.  | Fire Drills    | Pilla Ed Ctr                                  | Fire Drill  | 1 minute 56 seconds                                                                                                                                     |   |
| 11/4/2022                      | 9:30 p.m.  | Fire Alarm     | Smith Hall 150                                | Alarm       | Birthday candles set off alarm                                                                                                                          | 0 |
| 11/5/2022                      | 8:35 p.m.  | Fire Alarm     | Grace Hall 204                                | Alarm       | Students guest vaping set off alarm                                                                                                                     | 0 |
| 11/11/2022                     | 7:41 p.m.  | Fire Alarm     | Smith Hall foyer                              | Alarm       | Student pulled manual fire alarm because she<br>was locked out of the dorm- security phone just<br>outside the entrance to Smith dorm was<br>functional | 0 |
| 12/1/2022                      | 1:26 a.m.  | Fire Alarm     | Grace Hall room213                            | Fire Alarm  | Student was vaping in room 213, 1 student failed<br>to evacuate, student advised she did not hear the<br>alarm or see the flashing lights               | 0 |
| 1/18/2023                      | 1:00 p.m.  | Fire Drills    | All buildings                                 | Fire Drill  | Evac Times: Mullen 5:33, Besse 6:44, PH 2:25,<br>Dauby 2:30, Stano 1:45, Pilla 2:46, Grace 3:10,<br>2:02, Smith 2:40                                    |   |
| 1/30/2023                      | 2:30 p.m.  | J202301302023  | Murphy Hall                                   | Fire Alarm  | Cleaning closet area tripped, no cause found                                                                                                            |   |
| 1/30/2023                      | 7:00 p.m.  | J202310302023b | Smith Hall                                    | Fire Alarm  | Res. Of 170 was cooking and the food smoked<br>quickly setting off the alarm, no fire present                                                           |   |
| NO INCIDENTS FOR FEBRUARY 2023 |            |                |                                               |             |                                                                                                                                                         |   |
| 4/19/2023                      | 5:50 p.m.  | A202304192023  | Grace Hall                                    | Fire Alarm  | room 215 alarm set off by hair equipment                                                                                                                | 0 |
| 4/20/2023                      | 1:45 p.m.  | DRILLS         | Campus Wide                                   | Fire Drills | Evac times: Mullen 3:41, Besse 3:15, PH 1:41,<br>Dauby 3:08, Stano 1:22, Pilla 2:32, Grace 3:00,<br>Murphy 2:49, Smith 3:48                             |   |
| 4/20/2023                      | 9:05 p.m.  | A202304202023  | Pilla Center                                  | Fire Alarm  | 2nd floor pull station malfunction, FD reset                                                                                                            |   |
| No Incidents May, 2023         |            |                |                                               |             |                                                                                                                                                         |   |
| 6/15/2023                      | 4:50 a.m.  | J202306152023  | Murphy Hall                                   | Fire Alarm  | Alarm set off by student resident using hair<br>straightener, no fire present                                                                           |   |

|                            |            |                    |                                     |            |                                                                                                                                                                                                                                     |  |
|----------------------------|------------|--------------------|-------------------------------------|------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| 6/24/2023                  | 2:44 p.m.  | J202306242023      | Smith Hall                          | Fire Alarm | Alarm set off by camp member cooking Smith 320                                                                                                                                                                                      |  |
| 7/18/2023                  | 1:41 p.m.  | J202307182023      | Mullen                              | Fire Alarm | Alarm set off by dust from brick contractor, PPF reset                                                                                                                                                                              |  |
| 8/14/2023                  | 1040 a.m.  | DRILLS             | Grace Hall                          | Fire Drill | RA training                                                                                                                                                                                                                         |  |
| 8/31/2023                  | 1:00 p.m.  | Fire Drills        | Stano, Dauby, Parker, Besse, Mullen | Fire drill | Evac times: Stano 1:24, Dauby 2:17, Parker 2:09, Besse 2:21, Mullen 3:24                                                                                                                                                            |  |
| 9/1/2023                   | 10:00 a.m. | Fire Drills        | Pilla, Grace, Murphy, Smith         | Fire drill |                                                                                                                                                                                                                                     |  |
| 10/4/2023                  | 1145 am    | fire alarm         | murphy hall                         | alarm drop | PPFD responded unknow cause, building completely evacuated                                                                                                                                                                          |  |
| 10/10/2023                 | 1:22 AM    | fire alarm         | Grace Hall                          | alarm drop | PPFD responded unknow cause, building evacuated, report of some residents sleeping through the alarm                                                                                                                                |  |
| NO INCIDENTS NOVEMBER 2023 |            |                    |                                     |            |                                                                                                                                                                                                                                     |  |
| NO INCIDENTS DECEMBER 2023 |            |                    |                                     |            |                                                                                                                                                                                                                                     |  |
| 1/11/2024                  | 9:40 AM    | J202401112024      | Smith Hall                          | alarm drop | Resident of smith 140A set off alarm using heated hair appliance                                                                                                                                                                    |  |
| 1/19/2024                  | 11:30 AM   | J202401192024A     | Smith Hall                          | alarm drop | 3rd floor stove residents cooking burned pancakes, FD reset alarm                                                                                                                                                                   |  |
| 1/19/2024                  | 9:28 PM    | J202401192024B     | Smith Hall                          | alarm drop | Residents cooking, burned food setting off the alarm. FD shut down the stove since it was 2nd time here for burned food at same location                                                                                            |  |
| 1/31/2024                  | 11:51 AM   | J202401312024      | Smith Hall                          | alarm drop | residents cooking using an air fryer in suite 260, visible smoke in the suite, FD cleared the alarm board                                                                                                                           |  |
| 2/8/2024                   | 8:30 PM    | Evening Fire drill | Smith Hall, Murphy Hall, Grace Hall | Fire Drill | Evacuation times: Smith 4:02, Murphy 2:33, Grace 3:17                                                                                                                                                                               |  |
| 3/8/2024                   | 2:23 AM    | M202403082024      | Grace Hall 208                      | Fire Alarm | Room 208 smoke indicated, smoke filled room with odor of marijuana, resident not on scene. Lighters and small amount of suspected marijuana present on a table.                                                                     |  |
| 3/21/2024                  | 11:04pm    | M202403212024      | Grace Hall                          | Fire alarm | Residents of 312 had a space heater, RA confiscated it. PPF cleared the alarm board                                                                                                                                                 |  |
| 4/10/2024                  | 5:40 AM    | A202404102024      | Murphy Hall                         | Fire Alarm | Room 110 burnt toast set off fire alarm, FD reset the alarm board                                                                                                                                                                   |  |
| 4/16/2024                  | 6:pm       | A202404162024      | smith hall                          | Fire Alarm | Resident of 230A hair dryer set off alarm, FD reset alarm board                                                                                                                                                                     |  |
| 4/25/2024                  | 10:20am    | Fire Drills        | all buildings                       | fire drill | Fire Drill conducted all buildings: Evac times, Stano 1:20, Dauby 2:07, Parker Hannifin 1:36, Besse Library 2:35, Mullen 3:46 MU 130 caused failure to due test takers not evac, Frace Hall 3:29, Murphy Hall 2:34, Smith Hall 5:11 |  |
| 5/16/2024                  | 5:50pm     | fire alarm         | Smith Hall                          | Fire Alarm | A young child guest of a resident activated the emergency pull station in the lobby of Smith Hall. PPF reset the alarm panel                                                                                                        |  |
| 6/8/2024                   | 10:04 PM   | fire alarm         | Murphy Hall                         | Fire Alarm | Person overcooked items in microwave setting off fire alarm, FD reset the alarm panel                                                                                                                                               |  |
| 8/26/2024                  | 9:03 p.m.  | fire alarm         | Grace Hall                          | Fire alarm | Air Fryer was being used in room 213 set off alarm, FD reset the alarm panel                                                                                                                                                        |  |

|            |           |                |                                            |             |                                                                                                                       |  |
|------------|-----------|----------------|--------------------------------------------|-------------|-----------------------------------------------------------------------------------------------------------------------|--|
| 8/30/2024  | 9:30 a.m. | fire alarm     | Grace Hall                                 | Fire Alarm  | Room 220 fire alarm set off by hair straightener, FD reset the alarm panel                                            |  |
| 9/4/2024   | 1:15 PM   | Fire Drills    | Grace, Smith, & Murphy hall                | Fire drills | Smith 1:58, Murphy 1:57, Grace 2:38                                                                                   |  |
| 9/4/2024   | 8:51 PM   | S202409042024A | Grace Hall                                 | alarm drop  | Alarm in room where residents were using a vacuum, no cause was evident, FD reset panel                               |  |
| 9/4/2024   | 10:57 PM  | S202409042024B | Murphy Hall                                | alarm drop  | Room 110, hair straightener in use which set off the alarm, FD reset panel                                            |  |
| 9/5/2024   | 10:15 AM  | Fire Drills    | Stano, Dauby, Parker, Besse, Mullen, Pilla | Drills      | Stano 58 seconds, Dauby 1:44, Parker 1:29, Besse 2:07, Mullen 2:15, Pilla 2:21                                        |  |
| 9/17/2024  | 5:40 PM   | fire alarm     | Grace Hall                                 | alarm drop  | Fire alarm in room 312, residents stated they were using Febreeze, FD reset the alarm panel                           |  |
| 9/26/2024  | 11:22 PM  | S202409262024  | Grace Hall                                 | alarm drop  | Room 213, candle and lighter found in the room, items confiscated by RLC. FD reset the alarm                          |  |
| 10/4/2024  | 4:24PM    | O202410042024  | Grace Hall                                 | alarm drop  | Room 222, overheated hair dryer set off alarm, FD reset alarm                                                         |  |
| 10/16/2024 | 5:13 PM   | O202410162024  | Grace Hall                                 | alarm drop  | Room 203, overheated hair dryer, FD reset alarm panel                                                                 |  |
| 10/22/2024 | 7:55 AM   | O202410222024  | Grace Hall                                 | alarm drop  | Room 223, diffuser the likely cause, FD reset alarm panel                                                             |  |
| 11/5/2024  | 7:18 AM   | N202411052024  | Smith Hall                                 | Alarm drop  | Room 340D, hair straightener in use set off alarm, FD reset panel                                                     |  |
| 11/19/2024 | 8:02 PM   | N202411192024  | Grace Hall                                 | Alarm Drop  | Room 350 cooking set off alarm, FD reset the alarm panel                                                              |  |
| 11/20/2024 | 1:12 PM   | N202411202024  | Murphy Hall                                | Alarm Drop  | Room 310 hair dryer set off alarm, FD reset the alarm panel                                                           |  |
| 11/25/2024 | 7:50PM    | N202411252024  | Grace Hall                                 | Alarm Drop  | Room 218 hair appliance in use set off the alarm, FD reset the panel                                                  |  |
| 12/9/2024  | 9:30pm    | D202412092024  | Grace Hall                                 | Alarm Drop  | Room 208, aerosol can may have been the cause of the alarm activation. FD reset the panel.                            |  |
| 1/19/2025  | 5:52PM    | J202501192025  | Murphy Hall                                | Alarm Drop  | Laundry room, no cause found by FD, FD reset panel                                                                    |  |
| 1/24/2025  | 12:15 AM  | J202501242025  | Grace Hall                                 | Alarm Drop  | Hair Dryer in a room not listed on the report was the cause, FD reset the alarm panel                                 |  |
| 1/31/2025  | 11:35PM   | J202501312025  | Grace Hall                                 | Alarm Drop  | Hair Straightener in use Grace #219, FD responded, checks ok, FD reset panel                                          |  |
| 2/4/2025   | 9:45PM    | F202502042025  | Grace Hall                                 | Alarm Drop  | Possibly hair dryer set off alarm, FD reset                                                                           |  |
| 2/5/2025   | 6:00AM    | F202502052025A | Grace Hall                                 | Alarm Drop  | Unknown cause, poss. Bad smokehead. FD reset. Grace 303                                                               |  |
| 2/5/2025   | 6:04AM    | F202502052025B | Grace Hall                                 | Alarm Drop  | Unknown cause, poss. Bad smokehead. FD reset. Grace 303                                                               |  |
| 2/9/2025   | 7:52PM    | F202502092025  | Murphy Hall                                | Alarm Drop  | Laundry room, no cause found by FD, FD reset panel, recommend keeping laundry room door closed to to heat from dryer  |  |
| 2/11/2025  | 5:08PM    | F202502112025A | Grace Hall                                 | Alarm Drop  | Room 222, possible aerosol spray set alarm off, FD reset the panel                                                    |  |
| 2/11/2025  | 5:25PM    | F202502112025B | Grace Hall                                 | Alarm Drop  | Room 222, possible aerosol spray set alarm off, FD reset the panel smoke head to be checked on 2/12/25 by maintenance |  |

|           |             |                    |                                      |                 |                                                                                                                                                                    |  |
|-----------|-------------|--------------------|--------------------------------------|-----------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| 3/4/2025  | 1035-1137am | Fire Drills        | All buildings                        | Fire Drill      | Smith Hall 3:15, Murphy Hall 3:03, Grace Hall 3:55, Pilla 2:00, Stano 1:40, Dauby 1:47, Parker 1:21, Besse 2:09, Mullen 3:23                                       |  |
| 3/18/2025 | 8:50pm      | evening fire drill | Grace, Murphy, Smith Residence Halls | Fire Drill      | evening fire alarm drill conducted evacuation times: Smith 4:40, Murphy 3:31, Grace 5:37                                                                           |  |
| 3/19/2025 | 9:05PM      | M202503192025      | Grace Hall                           | Fire Alarm drop | Room 238 flat iron in use, FD reset panel                                                                                                                          |  |
| 3/27/2025 | 4:05PM      | M202503272025      | Grace Hall                           | Alarm Drop      | Spray deodorant set off smokehead in Room 223, FD reset the panel                                                                                                  |  |
| 3/29/2025 | 2:34PM      | M20250329025       | Grace Hall                           | Alarm Drop      | room 203 hair straightener in use, FD reset the panel                                                                                                              |  |
| 4/5/2025  | 8:23PM      | A202504052025      | Murphy Hall                          | Alarm Drop      | 1st floor laundry room, unknown cause, FD reset the fire panel                                                                                                     |  |
| 4/6/2025  | 4:45PM      | A202504062025A     | Murphy Hall                          | Alarm Drop      | 1st floor laundry room, unknown cause, FD reset the fire panel                                                                                                     |  |
| 4/6/2025  | 11:27PM     | A202504062025B     | Grace Hall                           | Alarm Drop      | Room 216, Vape pen found, was possible cause, vape pen confiscated. FD reset the panel                                                                             |  |
| 4/7/2025  | 8:00 PM     | A202504072025      | Grace Hall                           | Alarm Drop      | Room 237, nothing found by FD, FD reset the panel                                                                                                                  |  |
| 4/29/2025 | 3:47AM      | A202504292025      | Mullen                               | Alarm Drop      | 314 kiln room, vents not on causing room temp. increase. FD reset panel , vents turned on by security                                                              |  |
| 4/29/2025 | 12:12PM     | A202504292025B     | Grace Hall                           | Alarm Drop      | Room 219, unknown cause, FD mentioned smell of Vanilla in the room. FD reset the panel                                                                             |  |
| 5/2/2025  | 9:41 PM     | M202505022025      | Grace Hall                           | Alarm Drop      | 238 flat iron in use, FD reset panel, resident advised to open window & turn fan on.                                                                               |  |
| 5/19/2025 | 5:30 PM     | M202505192025      | Grace Hall                           | Alarm Drop      | Painters in Grace Hall set off fire alarm, system was placed in test until 8pm                                                                                     |  |
| 6/13/2025 | 244pm       | J202506132025      | Grace Hall                           | Alarm Drop      | Cooking in kitchen, burnt food was the cause, FD reset the alarm panel                                                                                             |  |
| 7/2/2025  | 905am       | J202507022025      | Grace Hall                           | Alarm Drop      | Contractors kicked up dust setting the smokehead off, room 240, FD reset the panel                                                                                 |  |
| 7/25/2025 | 2:07 AM     | J202507252025      | Grace Hall                           | Alarm Drop      | 1st floor common area kitchen, unknown cause, FD reset the fire panel                                                                                              |  |
| 7/28/2025 | 7:20PM      | J202507282025      | Grace Hall                           | Alarm Drop      | 1st floor kitchen, possible cause is condensation due to heavy rains, Precision alarm will be out ASAP to check the smokehead at this location. FD reset the panel |  |
| 7/29/2025 | 3:37PM      | J202507292025      | Grace Hall                           | Alarm Drop      | Kitchen Hall 1st floor, unkown cause, FD reset panel. New Smokehead to be installed                                                                                |  |
| 8/12/2025 | 1:27PM      | DRILL              | Grace Hall                           | Drill           | Fire drill with RA team and Pepper Pike safety forces                                                                                                              |  |
| 8/12/2025 | 1:47PM      | DRILL              | Grace Hall                           | Drill           | Fire drill with RA team and Pepper Pike safety forces                                                                                                              |  |
| 8/21/2025 | 6:30PM      | A202508212025      | Grace Hall                           | Alarm Drop      | Room 237 hair dryer in use, heat set off the alarm, FD reset the panel                                                                                             |  |

|           |             |               |                                                   |             |                                                                                                                                                              |  |
|-----------|-------------|---------------|---------------------------------------------------|-------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| 8/23/2025 | 8:13AM      | A202508232025 | Grace Hall                                        | Alarm Drop  | Alarm in 318, unknown cause, panel would not reset. Precision Alarm sent a tech, tech was able to reset the panel. 318 had the smokehead replaced            |  |
| 8/25/2025 | 4:59PM      | A202508252025 | Grace Hall                                        | Alarm Drop  | Alarm in Grace Hall kitchen, resident was cooking food and left it unattended. Burnt food was removed, FD ventilated the area due to smoke. FD reset system. |  |
| 8/27/2025 | 4:23PM      | A202508272025 | Murphy Hall                                       | Alarm Drop  | Room 102 hair straightener brush in use set off the detector, building evacuated, FD personnel reset the alarm panel.                                        |  |
| 8/30/2025 | 5:41 PM     | A202508302025 | Murphy Hall                                       | Alarm Drop  | Room 105 smokehead set off, no apparent reason for the activation, FD reset the alarm panel                                                                  |  |
| 9/2/2025  | 12:47pm     | S202509022025 | Smith Hall                                        | Alarm Drop  | Room 310D, Hair dryer/straightener in use, vape pen also located by FD personel. FD reset the alarm panel                                                    |  |
| 9/3/2025  | 1:05am      | S202509032025 | Grace Hall                                        | Alarm Drop  | Room 241, unknown cause, FD smelled a flowery spray smell. FD reset the alarm panel                                                                          |  |
| 9/3/2025  | 9:20-9:55am | DRILLS        | Pilla Center, Stano, Dauby, Parker, Besse, Mullen | Fire drills | Evac times; Pilla-1:45, Stano-1:24, Dauby 1:44, Parker 1:55, Besse 2:30, Mullen 2:14                                                                         |  |
| 9/3/2025  | 1pm-1:32pm  | DRILLS        | Smith, Murphy, & Grace Halls                      | Fire drills | Evac times; Smith- 3:06, Murphy-2:19, Grace-4:02                                                                                                             |  |