

Monthly Fire Log for 2015-2021						
Date	Time	Report Number	Location	Description	Disposition	Damage Est.
1/28/15	9:02 PM	J2015 1282015	Smith dorm	Alarm drop Candles burning	PPFP responded candles removed from room student informed of rules on candles	\$0
2/17/15	11:30	F20152172015	Library	Alarm drop burnt popcorn	PPFD responded burnt popcorn in microwave Alarm re-set	\$0
2/20/15	10:00	F2015202202015	Dorms	Fire Drills system check	Smith, Grace, Murphy	
3/11/15	10:00 PM	M201503112015	Pilla	Alarm drop from kitchen area	Guard responded and found a pot smoking. PPFD arrived after he removed source of smoke from the building. PPFD set up fans to exhaust smoke from the area re-set alarm once smoke was cleared.	\$50.00 est.
3/12/15	11:55 AM	M201503122015	Library	Alarm drop ground floor	PPFD responded found smoke detector in electrical closet went off do to drilling dust, cleared the dust and re-set alarm	\$0
3/10/15	12:30				Fire alarm testing & Drill Grace, Murphy, Smith	
4/15/15	9:30 AM	A201504152015	Dorms	Fire Drills	Grace, Smith, Murphy	
5/12//2015	11AM			Fire drills Mullen Besse Dauby		
5/11/15	9:30 AM			Fire Drills Pilla		
5/16/15	2:51 AM	J201505162015	Besse	Alarm drop smoke head hallway	PPFP responded, faulty head cleared and re-set	0
6/16/15	2:35 AM	J201506162015	Besse	Alarm drop	PPFD responded re-set clear	0
6/15/15	1:08 AM	J20156162015	Besse	Alarm drop	PPFD responded re-set clear	0
8/22/15	1:00PM	A201508222015	Dorm Area	Report of a trouble alarm on panel	National fire checked system and found a smoke detector tampered with and remounted detector	0
10/20/15	12:30pm - 1:35pm		Mullen, Besse, Stano, Parker, Dauby, Pilla	Fire Drills		0
10/23/15	7AM	O201510232015	Besse	Alarm drop	Smoke alarm basement level, PPFD responded re-set system	0
11/24/16	10:30 AM		Smith Grace, Murphy	Fire Drills		
4/13/16	7:15 PM		Besse library	Fire Drill		
4/24/16	3:00PM	A201604242016	Grace Dorm	Alarm Drop	Microwave oven overheated PPFD responded cleared smoke and re-set alarm	0
4/24/16	9:30 AM		Pilla, Stano, <Dauby	Fire Drills		
4/24/21016	2:15		Mullen, Besse	Fire Drills		
4/29/16	9:45 AM		Grace, Murphy, Smith	Fire Drills		
5/23/16	1:04 AM	M2016 5232016	Murphy Dorm	Alarm Drop	Hair spray set off alarm PPFD responded and re-set alarm	0
8/18/2016	9:24 PM	A20168182016	Smith Dorm	Alarm Drop	Hair dryer set off alarm PPFD responded and re-set alarm	0
9/11/16	5:52 PM	S20169112016	Grace Dorm	Alarm Drop	Hair dryer and Hair straightener over heated	0
9/11/16	12:30 PM	S02619112016B	Murphy Dorm	Alarm Drop	Smoke detector battery appeared to be weak replaced battery but went off again 1 hour later. Detector replaced	0
9/16 2016	11:30 AM		Grace Dorm	Fire drill		0
11/6/16	10:41 AM		Besse library	Alarm Drop	Alarm drop due to power outage PPFD re-set alarm	0
1/12 2017	1:00 PM	J20160122016	Mullen Bldg.	Microwave Overheated	Received a call of smoke on third floor. Food in microwave over cooked smoke cleared from area	0
4/28/17	10:00 AM		Dorm area	Fire drills		0
5/5/17	10:15 AM	False alarm	Library	Alarm Drop	Alarm went off at the library. PPFP responded checked the building and re-set the alarm.	0
8/21 2017	9:05 AM		Smith Dorm	Alarm Drop	Alarm at Smith dorm PPFD responded checked building re-set alarm, possible hair dryer overheated	0
9/22/17	10:00 AM	Fire Drills	Dorm Area	Fire drills		
10/5/17	6:50 PM	O201710052017	Grace Dorm	Alarm Drop	Flat iron Overheated Alarm re-set	0
10/13/17	5:10 PM	O20170132017	Grace Dorm	Alarm Drop	Flat Iron overheated PPFD re-set alarm	0
10/28/17	6:50 PM	O201710282017	Grace Dorm	Alarm Drop	Flat Iron overheated PPFD re-set alarm	0
12/2/17	9:00 PM	D201712022017	Grace Dorm	Alarm Drop	Flat Iron overheated PPFD re-set alarm	0
3/3/18	9:20 AM	Fire Drills	Pilla /Acd. Buildings	Fire Drill		
3/17/18	10:35 PM	M201803172018	Grace dorm	Alarm Drop	Unknown reason/system re-set	0
4/7/18	5:40 PM	A201804072018	Smith Dorm	Alarm Drop	Over cooked popcorn PPFD re-set alarm	0
6/13/18	9:45 AM	Fire Drills	Mullen	Pull station pulled	system re-set	0
7/11/18	10:45 PM	alarm pulled	Mullen	Pull station pulled	Accidental /system re-set	0
8/30/18	5:50PM	alarm Drop	Grace Dorm	Alarm Drop	Overheated hair dryer System Re-Set	0
9/15/18	4:30 PM	Alarm Pulled	Stano	Pull Station Pulled	Child pulled station PPFD re-set system	0
9/19/18	11:15 PM	Alarm drop	Dauby	Alarm Drop	unknown System Re-set	0
10/17/18	8:55 AM	Alarm Drop	Dauby	Alarm Drop	Power outage PPFD responded Re-set	0
10/17/18	8:55AM	Alarm Drop	Mullen	Alarm Drop	Power outage PPFD responded Re-set	0

11/20/18	11:25 AM	Alarm drop	Dauby	Alarm Drop	Power outage Re-set alarm	0
2/21/19	12:17 AM	Alarm Drop	Besse	Alarm Drop	Smoke head unknown reason, Re-set	0
6/10/19	2:45 PM	alarm Drop	Murphy	Alarm Drop	Construction dust PPFd responded and re-set	0
9/15/19	5:54pm	Alarm drop	Mullen	Electrical fire attic	PPFD arrived motor overheated in attic. Fire extinguished by maint. system re-set	\$400.00
9/20/19	10:20	Fire Drill	Murphy	Drill & test after Drill		0
9/23/19	12:35	Fire Drills	Grace Dorm	Drill		0
9/23/19	12:50	Fire Drills	Smith Dorm	Drill		0
10/30/19	8:30	Fire Drills	Dauby, Mullen Parker. Stano, Pilla	Drill	Completed between 8:30 & 9:30 AM	0
11/27/19	10:30	Fire Drills	Grace murphy Smith	Drill	Completed between 10:30 & 11:00	0
1/29/20	6:40 PM	Alarm Drop	Grace Dorm	Alarm Drop	PPFD notified overheated curling iron. System re-set	0
2/19/20	10:45 AM	Fire Drills	Grace ,Murphy,Smith	Drill	Completed between 10:45 -11:10	0
7/6/20	8:30	Test & Drill	Besse	Drill & test	Completed between 7:30 AM & 8:30	0
8/19/20	5:30 AM	Alarm Drop	Besse		PPFD arrived checked building / No alarm	0
9/17/20	10:00 AM	Fire Drills	Grace Murphy Smith	Fire drills	Completed between 10:00 AM & 11:45	0
11/5/20	10:30 AM	Alarm drop	Grace		Microwave overcooked food ,smoke on first floor. All residents evacuated and area cleared and re-set alarm	0
12/16/20	9Am		Mullen	Table Top & evacuation drill		0
12/16/20	11:00 AM	Fire Drills	Mullen, Besse,Parker ,Dauby, Stano,& Pilla	Drills & evac.	All Drills completed by 11:30 AM	0
1/13/21	10:14	Alarm drop	Grace		Received a Call from State alarm ,PPFD notified ,arrived on scene checked building .all residents evacuated . Third floor apt cleared caused undermined . Alarm re-set and cleared.	0
1/27/21	11:30	Fire Drills	Grace, Murphy		Completed by 12:00	0
4/30/21	9:25 AM	Fire Drills	Grace, Murphy Smith		All drills completed by 10:00Am	0
6/19/21	10:39 AM	Alarm Drop	Stano		PPFD responded and re-set alarm. Child pull a pull station	0

No incidents to report for July 2015, September 2015, and December 2015, January 2016, February 2016, March 2016, June 2016, July 2016, December 2016, February 2017, March 2017, June 2017, July 2017, November 2017, January 2018, February 2018, May 2018, December 2018, January 2019, March 2019, April 2019, May 2019, July 2019, August 2019, December 2019, April 2020, May 2020, June 2020, October 2020, February 2021, March 2021, May 2021, July 2021, August 2021, September 2021.